

Agency Information

The certificate is only used for browsing on the web and proves that SETsafe | SETfuse has been certified.

If you need a FULL-VERSION certificate, please contact us: sales@SETfuse.com

该证书只用于在网页浏览，证明SETsafe | SETfuse已获得认证，如需要完整版本证书，请联系我们: sales@SETfuse.com

Zertifikat

mit überwachter Konformität

Certificate

of surveyed conformity



Zertifikat Nr. *Certificate No.*
J 50493459

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

05-ZHANGVIVI-NN20028F 001 17.03.2021 *(day/mo/yr)*

Genehmigungsinhaber *License Holder*

Xiamen Set Electronics Co., Ltd.
No.8067, Xiangan Xi Road, Xiamen
Torch High-Tech Industrial Develop-
ment Zone, Xiangan Industry District
Xiamen
Fujian
P.R. China

Fertigungsstätte *Manufacturing Plant*

Xiamen Set Electronics Co., Ltd.
No.8001, Xiangan Xi Road,
Xiamen Torch High-Tech
Industrial Development Zone,
Xiangan Industry District, Xiamen,
Fujian
P.R. China

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*

EN 61643-11:2012+A11



Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

(Thermal-Link and MOV Combination (TMOV))

Type Designation : TFMOV20Mxxx
xxx are three numerical digits, which means Max. Continuous
Voltage (Uc) : 1) xxx=50 to 750
Details See Appendix 1

7

Trademark : SET
Uc : AC 50V-750V
Up : 400V-3300V
In : 20kA
Imax : 40kA
Type of SPD : type 2
Temperature range : -40°C to +85°C
Altitude : 5000m

Remark : The labelling requirements acc. to EU Directive
2001/95 have to be observed for distribution within the EEA.

7

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety

