

Agency Information

This certificate is only used for web browsing, proving that the SETsafe | SETfuse product has been certified.

For the full version, please contact: sales@SETfuse.com

Thank you for your support.



Product Service

Attestation of Conformity

No. N8A 107221 0011 Rev. 01

Model(s): **LFR01-xxA10-yy, LFR01-xxxA10-yy, LFR01-450A08-yy**

xx=50, 63, 80 and xxx=100, 125, 160, 200, 250, 315, 350, 400 denotes rated current 50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A respectively.

yy=BB, FB, BT, FE denotes different terminal type

BB: Bolt blade terminal

FB: Flat bolt terminal

BT: Bolt tag terminal

FE: Flush end terminal

LFG35-xxxA02-BT

xxx=100, 125, 160, 200, 250, 315, 350, 400, 450, 500, 550, 600 denotes rated current 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 600A respectively.

Parameters:

Model:	LFR01-xxA10-yy, LFR01-xxxA10-yy	LFR01-450A08-yy	LFG35-xxxA02-BT
Rated voltage:	DC1000V	DC800V	DC250V
Rated current:	50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A	450A	100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A, 450A, 500A, 550A, 600A
Rated breaking capacity:	50kA		
Poles No.:	1-P		
Breaking range and utilization category:	aR		

Tested according to:

EN 60269-1:2007/A2:2014
EN 60269-4:2009/A2:2016

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.