



中国国家强制性产品认证证书

证书编号：2026010308859006

认证委托人名称及地址

厦门赛尔特电子股份有限公司
厦门火炬高新区（翔安）产业区翔安西路 8067 号

生产者名称及地址

厦门赛尔特电子股份有限公司
厦门火炬高新区（翔安）产业区翔安西路 8067 号

生产企业名称及地址

厦门赛尔特电子股份有限公司
厦门火炬高新区（翔安）产业区翔安西路 8001 号

产品名称和系列、型号、规格

半导体设备保护用熔断体

SCF632CXxA500V; Un: AC500V; In: 20A, 25A, 30A, 35A, 40A; 额
定分断能力 I1: 50kA; 分断范围和使用类别: aR。型号解释见附页

产品标准和技术要求

GB/T 13539.4-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求，特发此证。

发证日期：2026 年 04 月 13 日 有效期至：2031 年 04 月 12 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

刘江



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2026010308859006

证书附页: 第 1 页 共 1 页

3.3 型号的解释:

<u>SCF632C</u>	<u>X</u>	<u>xA</u>	<u>500V</u>
1	2	3	4
1: 产品代码: 半导体设备保护用熔断体			
2: 安装方式			
P: 带尾线型			
Q: PT 型			
S: 贴片型			
缺省: 管状 (20A~30A)			
3: 额定电流: 20A, 25A, 30A, 35A, 40A			
4: 额定电压			

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2026010308859006

NAME AND ADDRESS OF THE APPLICANT

Xiamen' SET Electronics Co.,ltd

No. 8067 West Xiang'an Road Torch High-Tech Industrial District Xiang'an Xiamen Fujian Province P.
R. China

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen' SET Electronics Co.,ltd

No. 8067 West Xiang'an Road Torch High-Tech Industrial District Xiang'an Xiamen Fujian Province P.
R. China

NAME AND LOCATION OF THE FACTORY

Xiamen' SET Electronics Co.,ltd

No. 8001 West Xiang'an Road, Torch High-Tech Industrial District, Xiang'an, Xiamen, Fujian Province,
361101, P. R. China

PRODUCT NAME,MODEL AND SPECIFICATION

Fuse-links for the protection of semiconductor devices

SCF632CXxA500V; Un: AC500V; In: 20A, 25A, 30A, 35A, 40A; Rated breaking capacity
I1: 50kA; Breaking range and Utilization category: aR; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 13539.4-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Apr.13,2026

Valid until: Apr.12,2031

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2026010308859006

Appendix: Page 1 of 1

3.3 型号的解释:

<u>SCF632C</u>	<u>X</u>	<u>xA</u>	<u>500V</u>
1	2	3	4
1: 产品代码: 半导体设备保护用熔断体			
2: 安装方式			
P: 带尾线型			
Q: PT 型			
S: 贴片型			
缺省: 管状 (20A~30A)			
3: 额定电流: 20A, 25A, 30A, 35A, 40A			
4: 额定电压			

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.